Energy performance certificate (EPC)		
68 Ballymacilcurr Road Upperlands MAGHERA BT46 5TT	Energy rating	Valid until: 5 February 2034 Certificate number: 2217-3841-7345-4700-9658
Property type	Detached house	
Total floor area	102 square metres	

Energy rating and score

This property's energy rating is D. It has the potential to be D.

See how to improve this property's energy efficiency.

Score	Energy rating	Current	Potential
92+	Α		
81-91	B		
69-80	С		
55-68	D	59 D	59 D
39-54	E		
21-38	F		
1-20	G		

The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in Northern Ireland:

the average energy rating is D the average energy score is 60

Breakdown of property's energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Granite or whinstone, with internal insulation	Good
Wall	Cavity wall, with internal insulation	Good
Roof	Pitched, 150 mm loft insulation	Good
Roof	Flat, no insulation (assumed)	Very poor
Window	Fully double glazed	Good
Main heating	Boiler and radiators, oil	Average
Main heating control	Programmer, room thermostat and TRVs	Good
Hot water	From main system	Average
Lighting	Low energy lighting in all fixed outlets	Very good
Floor	Solid, no insulation (assumed)	N/A
Secondary heating	Room heaters, coal	N/A

Primary energy use

The primary energy use for this property per year is 228 kilowatt hours per square metre (kWh/m2).

How this affects your energy bills

An average household would need to spend **£1,606 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £0 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2024** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Impact on the environment	This property produces	6.6 tonnes of CO2	
This property's environmental impact ra E. It has the potential to be E.	g is This property's potential production	0.0 tonnes of CO2	
Properties get a rating from A (best) to (worst) on how much carbon dioxide (C they produce each year.	2) emissions by making th	You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.	
Carbon emissions	about average occupar	These ratings are based on assumptions about average occupancy and energy use.	
An average household 6 tonnes produces	CO2 People living at the pro amounts of energy.	perty may use different	

Changes you could make

Step	Typical installation cost	Typical yearly saving
1. Solar water heating	£4,000 - £6,000	£66
2. Solar photovoltaic panels	£3,500 - £5,500	£506

Help paying for energy improvements

You might be able to get a grant from the <u>Boiler Upgrade Scheme (https://www.gov.uk/apply-boiler-upgrade-scheme)</u>. This will help you buy a more efficient, low carbon heating system for this property.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Declan Diamond
Telephone	07921002828
Email	declandiamond@hotmail.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	ECMK	
Assessor's ID	ECMK300674	
Telephone	0333 123 1418	
Email	info@ecmk.co.uk	

About this assessment

Assessor's declaration	No related party
Date of assessment	3 February 2024
Date of certificate	6 February 2024
Type of assessment	RdSAP